

INNOVATIVE GEO-SERVICES, LLC

ENGINEERING GEOLOGY SERVICES
ENGGEOLIST.COM



Field Observation Report

Project Name Triton Homes Lot 10		Job TH-10 SFR	Inspection Report #1
Address / Parcel No. 22575 SE 52 nd ST		Date May 12, 2022	Page 1 of 1
City or County Issaquah, King	Permit # BLD21-00103	Arrival Time 10:00 am	
Client Triton Homes	Project Manager Rex Humphrey, L.E.G.		
Contractor Triton Homes	Field Inspector Rex Humphrey, L.E.G.		
Weather O/C 50's			
Type of Work Performed Foundation Soil Observations			
Equipment Used 5/8 in Soil Probe			

Observations:

Innovative GEO-Services, LLC (IGS) visited the new single family residential site to observe foundation soil and relative soil bearing for Lot 10. The foundation soil has been excavated and prepared for structural footings and foundation.


Foundation soils were probed throughout the excavation and appear to meet or exceed 2,000 psf recommended in the Geotechnical Evaluation dated June, 2021. Foundation soils appear to be ready for structural footings.

We appreciate the opportunity to be of service on this project. If you have any questions regarding this report or any aspects of the project, please feel free to contact our office.

Please feel free to call me at 253-279-4205 if you have any questions.

Respectfully Submitted,

Innovative GEO-Services, LLC



REX B. HUMPHREY

Rex Humphrey, L.E.G.
Engineering Geologist